



Clean Water Information System

- Account Settings
- More Information
- Logout

Event Search

Overflow / Bypass Event Details

Initial Report

Facility Name: Bolivar WWTF

Permit No: MO0022373

* Indicates a Required Field

**Indicates a Required Field for Final Report

Once you enter the Event End Date & Time fields and Add Event/Save Changes, you will no longer be able to edit this record!

Event Details

Bypass = at the wastewater treatment plant; Overflow = in the collection system

Confirmation No: 3711

*Type of Event: SSO (Overflow) ▼

*Wet or Dry Event? Dry ▼

*Event Begin Date: 09/03/2013 (MM/DD/YYYY)

*Event Begin Time: 15:00 (HH:MM) Military Time

**Event End Date: 09/03/2013 (MM/DD/YYYY)

**Event End Time: 15:10 (HH:MM) Military Time

Event Duration (hh:mm) 0d:0h:10m:

*Initial Report Date: 09/03/2013 (MM/DD/YYYY)

*Initial Report Time: 15:52 (HH:MM) Military Time

Discharged To: Ground ▼

*Reported By: James Bradsh

*Immediate Contact (417) 326 - 2489

Ongoing?: ☐

*Estimated Volume at time of Initial Report (gallons): 3000.00

Is bypass/overflow reaching Waters of the State? ☐

Affected Waterbody: **Cause of Event:

Cause of Event Comments: Submersible pump at lift station had air locked, from level being to low. Lift station 1.
(Maximum characters: 1000)
You have characters left.

Event Type: *** To select more than one choice hold down the control key on the keyboard**

Additional Impact:

Location InformationCounty: UTM Easting: UTM Northing:

* Location Description
(Maximum characters: 1000)
You have characters left.

Double click on the map to zoom in. The mouse wheel or the slider bar on the left side of the map may be used to zoom in or out. Use the arrow buttons on the edges of the map or hold down the left mouse button and drag the map to move to another location. Optionally, select a County, City or Zip Code from the drop downs to zoom to an area, OR you may enter an address (number street city) and select the 'Locate' button to zoom to that location.

County: City: Zip Code: Address:

Scale 1:2,400



Select the red indicator to activate the marking tool then single click on the map to mark the location of your event.



**5 - Day Report********Estimated Final Total Volume
(gallons):Did bypass reach Waters of
the State? ☐****Response:**(Maximum characters: 1000)
You have characters
left.

Pump has been repaired bubbler system failed, was put in float backup. James had spent a few cycles with it to make sure it will work properly.

Record added by: nr.bradj

[Add Additional Event](#)Department of Natural Resources
1-800-361-4827 / 573-751-1300E-mail: cleanwater@dnr.mo.gov
P.O. Box 176, Jefferson City, MO 65102